

DAYLIGHTING NOMOGRAPHS REVISITED

RADIANCE WORKSHOP, October 23 2009

LBL DAYLIGHTING NOMOGRAPHS


- Originated from the 1984 paper titled LBL Daylighting Nomographs by Selkowitz and Gabel
- Validated using DOE 2 measurements






Harvard Graduate School of Design

- Determine potential impact of daylighting in a commercial building.
- Flexibility in:
 - Latitude of location
 - Occupancy hours and schedule
 - Total building floor area
 - Daylight floor area
 - Visible Light transmittance of glazing
 - Glazing area
 - Choice of dimming or one step controls
 - Maximum dimming factor



Harvard Graduate School of Design




■ Daylight hours: 95%


■ Daylit area: 62%

■ Threshold Illumination level: 50 foot candles

■ TVIS * Area: 0.3

Annual Control Effectiveness: 61%





Harvard Graduate School of Design


■ Daylight hours: 95%


■ Daylit area: 62%

■ Threshold Illumination level: 50 foot candles

■ TVIS * Area: 0.3

Annual Control Effectiveness: 61%





Harvard Graduate School of Design


■ Daylight hours: 100%


■ Daylit area: 100%

■ Threshold Illumination level: 50 foot candles

■ TVIS * Area: 0.3

■ Annual Control Effectiveness: 61%







Harvard Graduate School of Design

RECREATING NOMOGRAPH RESULTS IN RADIANCE/ DAYSIM

The Nomograph parameters:

- Occupancy hours: 0800 to 1800
- Lighting Power Density: 1W/ sq ft
- No individual lighting controls, no blinds






Harvard Graduate School of Design

RECREATING NOMOGRAPH RESULTS IN RADIANCE/ DAYSIM

The Nomograph parameters:


- Occupancy hours: 0800 to 1800
- Lighting Power Density: 1W/ sq ft
- Lighting user: No individual controls
- Blind user: No blinds installed
- Threshold Illumination level: 50 foot candles





50 foot candles

Harvard Graduate School of Design

RECREATING NOMOGRAPH RESULTS IN RADIANCE/ DAYSIM







70 foot candles

ENERGY SAVINGS FROM DAYLIGHTING TODAY


The Nomograph parameters (1984):

- Lighting user: No individual controls
- Blind user: No blinds installed
- Reference: Lights always on

Daylight Autonomy Analysis with the above parameters

Parameters for practices today:


- Lighting user: Individual controls (Switches)
- Blind user: Blinds (inevitable)
- Lighting controls: Photo sensor controlled dimming system (How efficient?)
- Reference: Lights under individual controls



Daylight Autonomy Analysis with the above parameters

Harvard Graduate School of Design


ENERGY SAVINGS DUE TO OCCUPANT BEHAVIOR:



Private office, standard lighting system

Harvard Graduate School of Design


ENERGY SAVINGS DUE TO OCCUPANT BEHAVIOR:



Blinds Yes | Blind control Occupant | Lighting system On / Off | Lighting control Average Occupant

ENERGY SAVINGS DUE TO LIGHTING CONTROL SYSTEMS:

Blinds



100 90 ANNUAL CONTROL **EFFECTIVENESS** NOMOGRAPH FOR 50 FOOT CANLDES ANNUAL CONTROLEFFECTIVENESS (%) 70 ANNUAL CONTROL **EFFECTIVENESS** FROM RADIANCE/ DAYSIM 30 AVERAGE ANNUAL 20 CONTROL **EFFECTIVENESS** FROM RADIANCE/ DAYSIM 10

Private office, photo sensor controlled dimming stem


TVIS* AREA Private office, standard lighting system

0.2

Harvard Graduate School of Design


0.6

ENERGY SAVINGS DUE TO LIGHTING CONTROL SYSTEMS:



Blinds Yes | Blind control Occupant | Lighting system Dimming | Lighting control Average Occupant

ENERGY SAVINGS DUE TO OCCUPANTS:




Open plan office, photo sensor controlled dimming system

Private office, standard lighting system

Harvard Graduate School of Design


ENERGY SAVINGS DUE TO LIGHTING CONTROL SYSTEMS:



Blinds Yes | Blind control Occupant | Lighting system Dimming | Lighting control None | Open plan office


Harvard Graduate School of Design

ENERGY SAVINGS DUE TO OCCUPANT BEHAVIOR:



Blinds Yes | Blind control Occupant | Lighting system Dimming | Lighting control None | Open plan office Blinds Yes | Blind control Occupant | Lighting system On/ Off | Lighting control Average Occupant | Private Office

ENERGY SAVINGS DUE TO OCCUPANT BEHAVIOR:



Blinds Yes | Blind control Occupant | Lighting system Dimming | Lighting control Average Occupant | Private office Blinds Yes | Blind control Occupant | Lighting system Dimming | Lighting control None | Open Plan Office Blinds Yes | Blind control Occupant | Lighting system On/ Off | Lighting control Average Occupant | Private Office


■ Daylight hours: 95%

■ Daylit area: 62%

■ Threshold Illumination level: 50 foot candles

■ TVIS * Area: 0.3

■ Annual Control Effectiveness: 46%



Harvard Graduate School of Design

THANK YOU

RADIANCE WORKSHOP, October 23 2009